



TOP ENTRY CONDUIT PLATE

TOP CONDUIT INSTALLATION INSTRUCTIONS

1. REMOVE MOUNTING SCREWS FROM PLATE.
2. PUNCH OUT REQUIRED CONDUIT HOLES.
3. INSTALL CONDUIT AS REQUIRED.
4. REPLACE CONDUIT PLATE ON UNIT WITH MOUNTING SCREWS.

RECOMMENDED MAXIMUM TABLE AND CONDUIT SIZES

REFER TO THE CHART ON SHEET 2.
 THIS TABLE IS FOR REFERENCE ONLY. REFER TO APPLICABLE NATIONAL AND LOCAL ELECTRICAL CODES FOR TYPE AND SIZE OF CONDUITS AND CONDUCTORS TO USE FOR INSTALLATION.
 POWER AND CONTROL CABLES TO BE IN SEPARATE CONDUITS.
 CONTROL WIRES TO BE 16AWG UL/CSA.

SIZE	CAGE CODE	DWG NO.	REV.
B	9L985	90-160080-00	E02
SCALE	NONE	CAD	SHEET 3 OF 7